

SDSD Detention Services Bureau—San Diego Central Jail Green Sheet

DATE:	March 16, 2022
NUMBER:	I.35.C.1
SUBJECT:	HOUSING UNIT SPECIAL EQUIPMENT

PROCEDURE

At the beginning of each shift, the assigned deputy will check their Self-Contained Breathing Apparatus' (SCBA's) and make appropriate log entries under the Emergency Equipment Check to document the presence and condition of the equipment. If air tank is below 3500 PSI, replace the bottle. For a bottle replacement, SCBA damage, or concerns, email the facility administrative sergeant.

LOCATION	NUMBER	RESPONSIBLE
1 st Floor Intake Control	1	Intake Deputy
1 st Floor Fire Response Room	8	Intake Deputy
2 nd Floor CCC	2	CCC Deputy
2 nd Floor Processing Sergeant's Office	1	Processing Sergeant
3 rd Floor PSU	2	PSU Deputy
4 th Floor Housing	3	4 th Floor Housing/Control Deputy
5 th Floor Housing	3	5 th Floor Housing/Control Deputy
6 th Floor Housing	3	6 th Floor Housing/Control Deputy
7 th Floor Housing	3	7 th Floor Housing/Control Deputy
8 th Floor Housing	3	8 th Floor Housing/Control Deputy
9 th Floor Fire Response Room	10	Kitchen Deputy